

# BULLETIN MEMO



**DATE:** May 6, 2025

**PROJECT:** DVT Taxiway C Connectors C4-C10 (GMP 1 – C7 and C10) | AV31000096 ADOT

**RE:** BULLETIN NO. 01

---

## **BULLETIN NO. 01**

Bulletin No. 01 includes modifications requested by the Owner, PHX F&S Electrical, for additional plan review requests and modifications. Two of the requested modifications were not included in this Bulletin, and cannot be incorporated into the plan set for this project due to other conditions and FAA Standards. These modifications were changing the incandescent lights along Taxiway C to LED, and modifying one of the conduit pathways to 6 each 2" conduits in lieu of the specified 2 each 4" conduits. The 4" conduits are required to complete the work.

Sheet No.	Drawing No.	Title	Description of Revision
42	EA-102	AIRFIELD LIGHTING AND ELECTRICAL PLAN	TWO separate conduits from JC-1, one to feed sign -4 and one to feed to HH-1
44	EA-104	AIRFIELD LIGHTING AND ELECTRICAL PLAN	TWO separate conduits from JC-3, one to feed sign -11 and one to feed to HH-3. Labeled HH-4.

End of Bulletin No. 01.