


ATTENTION



ADDENDUM 1

BID OPENING: June 18, 2026

BID: SEDONA AIRPORT INFIELD RSA DRAINAGE IMPROVEMENTS IN YAVAPAI COUNTY, ARIZONA - PROJECT # 2555021



1. CLARIFICATION:

Bidder Questions (Q#) and Answers (A#):

Q1: RGRCP Alternate Materials. Will ADS HP polypropylene pipe be considered as an alternate to RGRCP on this project?

A1: Alternate pipe material not allowed. RGRCP required.

Q2: 6" PVC Under Drain Type. Can you advise what type of PVC is acceptable for this project and what the anticipated existing 6" PVC under drain is?

A2: New pipe for 6" PVC Edge Drain Pipe shall be in accordance with Specification Item D-701-2.2 Pipe and shall be Solid 6" PVC Pipe, SDR 26 or approved equivalent. All exposed PVC pipe shall be protected from ultraviolet degradation by application of two coats of light-colored, water-based acrylic paint compatible with PVC materials or elastomeric, UV-resistant coating system suitable for plastics, and applied per manufacturer's recommendations. SDR for existing 6" PVC underdrain pipe unknown.

Acknowledgement of this Addendum is required in the OpenGov Procurement Portal.